

APPENDIX K

Cost Breakdown

Appendix K1 – Mechanical Treatment Process Costs

Appendix K2 – Lagoon Treatment Process Costs

Appendix K1 – Mechanical Treatment Process Costs

Table K1 - Mechanical Treatment Process Capital, O&M and Life Cycle Cost Summary

Process	Sub-Total Capital Cost ¹	Contingency (15%)	Engineering (15%)	Total Capital Cost ¹	Annual O&M Cost ²	20-Year O&M ³	Life Cycle Costs ⁴
RBC	4,964,481	744,672	744,672	6,453,825	141,000	2,820,000	9,273,825
SBR	5,025,399	753,810	753,810	6,533,019	134,000	2,680,000	9,213,019
EA	5,278,833	791,825	791,825	6,862,483	153,000	3,060,000	9,922,483
CAS	5,216,744	782,512	782,512	6,781,768	151,000	3,020,000	9,801,768

Notes:

¹ See Table K2 - Mechanical Treatment Process Breakdown of Estimated Capital Costs

² See Table K3 - Mechanical Treatment Process Estimated Annual Operating Costs

³ 20-Year O&M Costs are calculated by multiplying the Annual O&M Cost by 20

⁴ Life Cycle Costs are calculated by adding the Total Capital Cost to the the 20-Year O&M Cost

Table K2 - Mechanical Treatment Process Breakdown of Estimated Capital Costs

	Treatment Plant Alternative			
	RBC	SBR	EA	CAS
General condition	\$310,106	\$310,106	\$310,106	\$310,106
Site work	\$534,204	\$968,440	\$1,046,540	\$968,440
Concrete	\$624,800	\$920,018	\$937,200	\$797,401
Miscellaneous metals	\$117,150	\$177,287	\$180,411	\$167,915
Pre-fabricated metal building	\$44,000	\$44,000	\$44,000	\$44,000
Process Equipment ¹	\$2,062,621	\$1,052,788	\$1,209,379	\$1,399,552
Mechanical	\$77,000	\$77,000	\$77,000	\$77,000
Electrical	\$468,600	\$749,760	\$748,198	\$726,330
Outfall sewer	\$726,000	\$726,000	\$726,000	\$726,000
subtotal	\$4,964,481	\$5,025,399	\$5,278,833	\$5,216,744
Contingency (15%)	\$744,672	\$753,810	\$791,825	\$782,512
Engineering (15%)	\$744,672	\$753,810	\$791,825	\$782,512
Total	\$6,453,825	\$6,533,019	\$6,862,483	\$6,781,767

Note

1- enclosure included in the cost of RBC equipment

Table K3 - Mechanical Treatment Process Estimated Annual Operating Costs

Extended Aeration Process						CAS Operating Costs Liquid Treatment System					
Equipment	Power (in kW)	No. of Units	Typ. Operating Hours (hrs)	Total Power per day(kWh)	Equipment	Power (in kW)	No. of Units	Typ. Operating Hours (hrs)	Total Power per day(kWh)		
Coarse Screen With grinder	3.5	1	20	70	Coarse Screen With grinder	3.5	1	20	70		
Septage Pump with VFD	2.5	1	8	20	Septage Pump with VFD	2.5	1	8	20		
Mixer (anoxic)	2	2	24	96	Mixer (anoxic)	2	2	24	96		
Aeration Blowers	19.5	2	24	936	Aeration Blowers primary/Secondary	10.3	2	24	494.4		
Secondary Clarifier Drive Unit	2	2	24	96	Clarifier Drive Unit	4	4	24	384		
RAS/WAS pumps	7.5	2	24	360	RAS/WAS pumps	7.5	2	24	360		
Scum Pumps	3	2	1	6	Scum Pumps	3	2	1	6		
Alum feed system-duty	0.3	1	24	7.2	Alum feed system-duty	0.3	1	24	7.2		
Alum feed system-standby	0.3	1	5	1.5	Alum feed system - standby	0.3	1	5	1.5		
UV	0.37	2	24	17.76	UV	0.37	2	24	17.76		
Automatic Samplers	0.25	1	2	0.5	Automatic Samplers	0.25	1	2	0.5		
Solids treatment System						Solids treatment System					
Digester Blowers	7.5	1	24	180	Digester Blowers	7.5	1	24	180		
Digested Sludge Transfer pump	2	1	1	2	Digested Sludge Transfer pump	2	1	1	2		
overall efficiency				0.8	overall efficiency				0.8		
Power costs per Kwh				0.1	Power costs per Kwh				0.1		
Sub Total power cost				\$ 156.88	Sub Total power cost				\$ 143.44		
chemical costs for treatment				\$ 63.84	chemical costs for treatment				\$ 63.84		
Annual Daily Operating Cost (power + chmical) at 900 m3/d				\$221	Total Daily Operating Cost (power + chmical) at 900 m3/d				\$207		
Annual (power + chmical) cost				\$81,900	Annual (power + chmical) cost				\$76,000		
Annual Labour cost ¹				47000	Annual Labour cost ²				\$49,835		
biosolids handling cost				\$24,379	biosolids handling cost				\$24,879		
Annual O&M cost				\$152,879	Annual O&M cost				\$150,714		

Notes:

¹ See Table K3(a) Extended Aeration Process Breakdown of Annual Labour Costs

² See Table K3(b) CAS Breakdown of Annual Labour Costs

³ See Table K3(c) SBR Process Breakdown of Annual Labour Costs

⁴ See Table K3(d) RBC Process Breakdown of Annual Labour Costs

Table K3 - Mechanical Treatment Process Estimated Annual Operating Costs

SBR-ISAM Operating Costs Liquid Treatment System		RBC Operating Costs Liquid Treatment System							
Equipment	Power (in kW)	No. of Units	Typ. Operating Hours (hrs)	Total Power per day(kWh)	Equipment	Power (in kW)	No. of Units	Typ. Operating Hours (hrs)	Total Power per day(kWh)
Coarse Screen With grinder	3.5	1	20	70	Coarse Screen With grinder	3.5	1	20	70
Septage Pump with VFD	2.5	1	8	20	Septage Pump with VFD	2.5	1	8	20
WasteSludge Pump	2.2	2	1.5	6.67	WasteSludge Pump	0.5	1	1.5	0.75
Aeration Blowers	20.02	2	15	600.6	motor	7.45	4	24	715.2
Aspirator Pump					primary/Secondary Clarifier Drive Unit	90			
Jet pumps	7.5	2	6			4	4	24	384
Equalization Tank Pumps	t1.12	2	4	88.92	Scum Pumps	88.92	3	2	6
Alum feed system- duty	7.5	1	18	135	Equalization Tank Pumps	7.5	1	18	135
Alum feed system - standby	0.3	1	24	7.2	Alum feed system-duty	0.3	1	24	7.2
UV	0.3	1	5	t.5	Alum feed system - standby	0.3	1	5	1.5
	0.37	2	24	17.76	UV	0.37	2	24	17.76
Automatic Samplers	0.25	1	2	0.5	Automatic Samplers	0.25	1	2	0.5
Decanter actuator	0.3705	2	2.5	1.8525	effluent pump	0.3705	1	24	8.892
Solids Treatment System					Solids Treatment System				
Digester Blowers	7.5	1	24	180	Digester Blowers	7.5	1	24	180
Digested Sludge Transfer pump	2	1	1	2	Digested Sludge Transfer pump	2	1	1	2
overall efficiency					0.8 0.1 Sub Total power cost				
Power costs per Kwh					Power costs per Kwh Sub Total power cost				
Sub Total power cost				\$ 106.93					
chemical costs for treatment					\$63.84 chemical costs for treatment				
Total DailyOperating Cos (power + chemical) at 900 m3/d					\$171	Total DailyOperating Cost (power + chemical) at 900 m3/d			
Annual (power + chemical) cost					\$62,000	Annual (power + chemical) cost			
Annual Labour cost ³					\$49,800	Annual Labour cost ⁴			
biosolids handling cost					\$22,617	biosolids handling cost			
Annual O&M cost					\$134,417	Annual O&M cost			

Notes:

¹ See Table K3(a) Extended Aeration Process Breakdown of Annual Labour Costs

² See Table K3(b) CAS Breakdown of Annual Labour Costs

³ See Table K3(c) SBR Process Breakdown of Annual Labour Costs

⁴ See Table K3(d) RBC Process Breakdown of Annual Labour Costs

Table K3(a) - Extended Aeration Process Breakdown fo Annual Labour Cost

item	Task	skills	weekly Average (hr.)
1 INITIAL OVERALL INSPECTION			
a	quick visual inspection	Operator II	0.56
b	check maintenance schedule	Operator II	0.28
c	record maintenance jobs	Operator I	0.25
2 CHECK AND MAINTAIN EQUIPMENT AND TANKS			
a	Maintain Inlet area		
	- hand cleaning of screens	helper	0.75
	- removal/disposal of debris	helper	0.5
	- communitor cleaning	operator I	0.5
	- communitor maintenance	Operator II	0.12
	- clean inlet area	helper	0.56
b	Maintain blower equipment		
	- check blower and equipment	operator I	0.28
	- clean filter	operator I	0.12
	- blower & pump oil change	operator II	0.06
c	Clean aeration tank		
	- check,scrap and hosedown aeration tank	helper	0.5
d	Maintain air and return equipment		
	- inspect equipment	operator II	0.56
	- clean air diffusers	helper	0.25
	- operate foam equipment	operator I	0.13
	- clean foam equipment	helper	0.12
	- adjust sludge return	operator II	0.38
	- clean sludge return	helper	0.5
	- operate skimmer return	operator I	0.16
	- clean skimmer return	helper	0.12
e	Clean clarifier		
	- clean sidewalks, weirs, and still box	helper	1.75
	- scrape clarifier hopper	helper	1.12
f	Sludge removal		
	- sludge wasting	operator II	1
	- disposal of sludge	operator I	2
	- clean sludge system	helper	0.5
g	Chlorinator maintenance		
	- inspect and adjust chlorinator	operator II	0.56
	- clean chlorinator and feed line	operator I	0.25
	- refill chlorinator system	operator I	0.25
h	chemical feed system maintenance		
	- inspect and adjust chemical feed system	operator II	0.67
	- clean chemical pump and feed line	operator I	0.25
	- refill chemical	operator I	0.25

Table K3(a) - Extended Aeration Process Breakdown fo Annual Labour Cost

i other			
- clean decks, weirs and troughs	helper		3.5
- clean and store maintenance equipment	helper		3.5

3 PERFORM TESTS AND MAINTAIN OPERATIONAL LOG

- influent characteristics	operator I	0.14
- aeration characteristics	operator II	0.56
- clarifier characteristics	operator II	0.14
- effluent characteristics	operator I	0.14
- 30 minute settleability test	operator II	1.12
- DO test	operator II	1.12
- pH test	operator I	0.56
- chlorine residual test	operator I	0.56
- BOD test	operator II	0.4
- suspended solids test	operator II	1
- daily flow	operator I	0.56
- other recordings	operator I	1.12
- maintain books and test site, other test preparations	operator II	3.5

4 MAKE OPERATIONAL ADJUSTMENTS

- remedial measures -other	operator II	1
----------------------------	-------------	---

5 FINAL AND PERIODIC OPERATION

- maintain control system	operator II	0.25
- clean up plant site	helper	4
- outside contacts and other maintenance	operator II	1.12

Reference

Table 16-2 of Wastewater Treatment Facilities for Sewered small Communities, EPA Process Design Manual

TOTALS

	rate/hr.	
helper (hr./wk)	17.67	\$12.0
operator I	7.52	\$25.0
operator II	14.40	\$35.0
annual labour cost	\$47,014	

Table K3(b) - CAS Breakdown of Annual Labour Costs

item	Task	skills	weekly Average (hr.)
1 INITIAL OVERALL INSPECTION			
a	quick visual inspection	Operator II	0.56
b	check maintenance schedule	Operator II	0.28
c	record maintenance jobs	Operator I	0.25
2 CHECK AND MAINTAIN EQUIPMENT AND TANKS			
a	Maintain Inlet area		
	- hand cleaning of screens	helper	0.75
	- removal/disposal of debris	helper	0.5
	- communitor cleaning	operator I	0.5
	- communitor maintenance	Operator II	0.12
	- clean inlet area	helper	0.56
b	Maintain blower equipment		
	- check blower and equipment	operator I	0.28
	- clean filter	operator I	0.12
	- blower oil change	operator II	0.06
c	Clean aeration tank		
	- check,scrap and hosedown aeration tank	helper	0.25
d	Maintain air and return equipment		
	- inspect equipment	operator II	0.56
	- clean air diffusers	helper	0.25
	- operate foam equipment	operator I	0.13
	- clean foam equipment	helper	0.12
	- adjust sludge return	operator II	0.38
	- clean sludge return	helper	0.5
	- operate skimmer return	operator I	0.16
	- clean skimmer return	helper	0.12
e	Clean clarifier		
	- clean sidewalks, weirs, and still box	helper	1.75
	- scrape clarifier hopper	helper	1.12
f	Sludge removal		
	- sludge wasting	operator II	1
	- disposal of sludge	operator I	2.2
	- clean sludge system	helper	0.5
g	Chlorinator maintenance		
	- inspect and adjust chlorinator	operator II	0.56
	- clean chlorinator and feed line	operator I	0.25
	- refill chlorinator system	operator I	0.25
h	chemical feed system maintenance		
	- inspect and adjust chemical feed system	operator II	0.67
	- clean chemical pump and feed line	operator I	0.25
	- refill chemical	operator I	0.25
i	other		
	- clean decks, weirs and troughs	helper	3.5
	- clean and store maintenance equipment	helper	3.5
3 PERFORM TESTS AND MAINTAIN OPERATIONAL LOG			
	- influent characteristics	operator I	0.14
	- aeration characteristics	operator II	0.56
	- clarifier characteristics	operator II	0.14
	- effluent characteristics	operator I	0.14
	- 30 minute settleability test	operator II	1.12
	- DO test	operator II	1.12
	- pH test	operator I	0.56
	- chlorine residual test	operator I	0.56
	- BOD test	operator II	0.4
	- suspended solids test	operator II	1
	- daily flow	operator I	0.56
	- other recordings	operator I	1.12
	- maintain books and test site, other test preparations	operator II	3.5

Table K3(b) - CAS Breakdown of Annual Labour Costs

4 MAKE OPERATIONAL ADJUSTMENTS

- remedial measures -other	operator II	1
----------------------------	-------------	---

5 FINAL AND PERIODIC OPERATION

- maintain control system	operator II	0.25
- clean up plant site	helper	4
- outside contacts and other maintenance	operator II	1.12

TOTALs

		rate/hr.
helper	17.42 hr/wk	\$15.0
operator I	7.72	\$25.0
operator II	14.40	\$35.0

annual labour cost	\$49,835
---------------------------	-----------------

Table K3 (c) - SBR Process Breakdown of Annual Labour Costs

item	Task	skills	weekly Average (hr.)
1 INITIAL OVERALL INSPECTION			
a	quick visual inspection	Operator II	0.56
b	check maintenance schedule	Operator II	0.28
c	record maintenance jobs	Operator I	0.25
2 CHECK AND MAINTAIN EQUIPMENT AND TANKS			
a	Maintain Inlet area		
	- hand cleaning of screens	helper	0.75
	- removal/disposal of debris	helper	0.5
	- communitor cleaning	operator I	0.5
	- communitor maintenance	Operator II	0.12
	- clean inlet area	helper	0.56
b	Maintain blower equipment		
	- check blower and equipment	operator I	0.28
	- clean filter	operator I	0.12
	- blower oil change	operator II	0.06
c	Clean aeration tank		
	- check,scrap and hosedown aeration tank	helper	0.5
d	Maintain air and return equipment		
	- inspect equipment	operator II	0.56
	- clean air diffusers	helper	0.25
	- operate foam equipment	operator I	0.13
	- clean foam equipment	helper	0.12
	- adjust sludge return	operator II	0.38
	- clean sludge return	helper	0.5
	- operate skimmer return	operator I	0.16
	- clean skimmer return	helper	0.12
e	Clean clarifier		
	- clean sidewalks, weirs, and still box	helper	1.75
	- scrape clarifier hopper	helper	1.12
f	Sludge removal		
	- sludge wasting	operator II	1
	- disposal of sludge	operator I	2
	- clean sludge system	helper	0.5
g	Chlorinator maintenance		
	- inspect and adjust chlorinator	operator II	0.56
	- clean chlorinator and feed line	operator I	0.25
	- refill chlorinator system	operator I	0.25
h	Chemical feed system maintenance		
	- inspect and adjust chemical feed pumps	operator II	0.672
	- clean feed line and pump and tank	operator I	0.25
	- refill chemical tank	operator I	0.25
i	other		
	- clean decks, weirs and troughs	helper	3.5
	- clean and store maintenance equipment	helper	3.5
3 PERFORM TESTS AND MAINTAIN OPERATIONAL LOG			
	- influent characteristics	operator I	0.14
	- aeration characteristics	operator II	0.56
	- clarifier characteristics	operator II	0.14
	- effluent characteristics	operator I	0.14
	- 30 minute settleability test	operator II	1.12
	- DO test	operator II	1.12
	- pH test	operator I	0.56
	- chlorine residual test	operator I	0.56
	- BOD test	operator II	0.4
	- suspended solids test	operator II	1
	- daily flow	operator I	0.56
	- other recordings	operator I	1.12
	- maintain books and test site, other test preparations	operator II	3.5

Table K3 (c) - SBR Process Breakdown of Annual Labour Costs

4 MAKE OPERATIONAL ADJUSTMENTS

- remedial measures -other	operator II	1
----------------------------	-------------	---

5 FINAL AND PERIODIC OPERATION

- maintain control system	operator II	0.25
- clean up plant site	helper	4
- outside contacts and other maintenance	operator II	1.12

TOTALS

		rate/hr.
helper	17.67 hr/wk	\$15.0
operator I	7.52	\$25.0
operator II	14.402	\$35.0
annual labour cost	\$49,770	

Table K3(d) - RBC Process Breakdown of Annual Labour Costs

item	Task	skills	weekly Average (hr.)
1 INITIAL OVERALL INSPECTION			
a	quick visual inspection	Operator II	0.56
b	check maintenance schedule	Operator II	0.28
c	record maintenance jobs	Operator I	0.25
2 CHECK AND MAINTAIN EQUIPMENT AND TANKS			
a	Maintain Inlet area		
	- hand cleaning of screens	helper	0.75
	- removal/disposal of debris	helper	0.5
	- communitor cleaning	operator I	0.5
	- communitor maintenance	Operator II	0.12
	- clean inlet area	helper	0.56
b	Maintain blower equipment		
	- check equipment	operator I	0.28
	- oil change	operator II	0.0612
c	Clean clarifier		
	- clean sidewalks, weirs, and still box	helper	1.75
	- scrape clarifier hopper	helper	1.12
d	Sludge removal		
	- sludge wasting	operator II	0.5
	- disposal of sludge	operator I	2.2
	- clean sludge system	helper	0.5
e	Chlorinator maintenance		
	- inspect and adjust chlorinator	operator II	0.56
	- clean chlorinator and feed line	operator I	0.25
	- refill chlorinator system	operator I	0.25
f	Chemical feed system maintenance		
	- inspect and adjust chemical feed pumps	operator II	0.672
	- clean feed line and pump and tank	operator I	0.25
	- refill chemical tank	operator I	0.25
g	other		
	- clean decks, weirs and troughs	helper	3.5
	- clean and store maintenance equipment	helper	3.5
3 PERFORM TESTS AND MAINTAIN OPERATIONAL LOG			
	- influent characteristics	operator I	0.14
	- aeration characteristics	operator II	0.56
	- clarifier characteristics	operator II	0.14
	- effluent characteristics	operator I	0.14
	- 30 minute settleability test	operator II	1.12
	- DO test	operator II	1.12

Table K3(d) - RBC Process Breakdown of Annual Labour Costs

- pH test	operator I	0.56
- chlorine residual test	operator I	0.56
- BOD test	opertor II	0.4
- suspended solids test	operator II	1
- daily flow	operator I	0.56
- other recordings	operator I	1.12
- maintain books and test site, other test preparations	operator II	3.5

4 MAKE OPERATIONAL ADJUSTMENTS

- remedial measures -other	operator II	1
----------------------------	-------------	---

5 FINAL AND PERIODIC OPERATION

- maintain control system	operator II	0.25
- clean up plant site	helper	4
- outside contacts and other maintenance	operator II	1.12

TOTALs

		rate/hr.
helper (hr./wk)	16.18	\$15.0
operator I	7.31	\$25.0
operator II	12.9632	\$35.0
annual labour cost	\$45,716	

Appendix K2 – Lagoon Treatment Process Costs

Table K4 - Lagoon Treatment Process Capital, O&M and Life Cycle Cost Summary

Lagoon Treatment Process Estimated Cost ¹	Foremain & Site Servicing ²	Outfall ³	Hydro Servicing	Sub-Total (15%)	Engineering Capital Cost	Estimated O&M ⁴	20-Year O&M ⁴	Life Cycle Costs ⁵
Area 1 \$2,265,500	\$2,107,789	\$1,945,229	\$108,900	\$6,427,418	\$964,113	\$7,392,000	\$2,180,000	\$9,572,000
Area 2 \$2,265,500	\$2,569,076	\$271,084	\$168,300	\$5,273,960	\$791,094	\$6,065,000	\$2,060,000	\$8,125,000
Area 3 \$2,265,500	\$3,678,299	\$3,214,895	\$220,000	\$9,378,694	\$1,406,804	\$10,785,000	\$2,380,000	\$13,165,000
Area 4 \$2,265,500	\$4,071,593	\$855,525	\$276,100	\$7,468,718	\$1,120,308	\$8,589,000	\$2,440,000	\$11,029,000
Area 5 \$2,265,500	\$4,471,533	\$855,525	\$331,100	\$7,923,658	\$1,188,549	\$9,112,000	\$2,400,000	\$11,512,000

Notes:

¹See Table K5 Capital Cost Breakdown for Aerated Lagoon at Area 1, 2, 3, 4, 5, includes 15% contingency allowance.

²See Table K6 Lagoon Site Servicing & Foremain Costs

³See Table K7 Lagoon Site Outfall Cost Estimate

⁴See Table K8 Annual O&M Cost Estimate For Lagoon Treatment Process

⁵ Life Cycle Costs are calculated by adding the Estimated Capital Cost and 20-Year O&M Costs

Table K5 - Capital Cost Breakdown for Aerated Lagoon at Area 1, 2, 3, 4 or 5

Division 1

general condition (7%)	\$135,100
Performance bond and insurance (0.8%)	\$15,520
Sub-total General Condition of contract	\$150,620

Division 2

Clearing and grub	\$63,756
stripping and stockpiling	\$34,650
Excavating trenching grading and filling	\$560,399
synthetic liner	\$398,030
Siltation control and storm mgmt	\$1,650
sluice gates	\$21,450
interconnecting sewers	\$33,000
precast conc. chambers	\$24,200
Tree, Seed and Sod, Top soil and Sod	\$6,794
access road	\$33,000
chain link fencing and gate	\$80,164
subtotal-site works	\$1,257,091

Division 3- Concrete Sub-total	\$59,400
---------------------------------------	-----------------

Building-sub-total	\$33,000
---------------------------	-----------------

Miscellaneous Metals- sub-totals	\$22,000
---	-----------------

Division 11

General Clauses & Inst.	\$6,600
aeration equipment	\$154,000
chemical feed system	\$65,340
subtotal -process equipment	\$225,940

general mechanical	
mechanical system controls	
sub-total- mechanical	\$6,600

Division 16	
electrical sub-totals	\$220,000

Total	\$1,970,000
contingency (15%)	\$295,500
engineering (15%)	\$295,500
Total	\$2,561,000

Table K6 - Lagoon Force main & Site Servicing Costs

Area 1

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of Force main	900 m	330	297,000
Gas Pipeline Crossings	0 each	247,500	0
Rail Crossings	1 each	357,500	357,500
Creek Crossings	0 each	16,500	0
# of Lift Stations c/w genset	1 each	770,000	770,000
Road Reconstruction	700 m	220	154,000
Service Road Construction	200 m	440	88,000
Highway Crossing	0	126,500	0
Telephone	200 m	33	6,600
Electricity	200 m	110	22,000
Water - municipal service	200 m	220	44,000
sub-total			1,739,100
Genral condition of contract			107,824
Contingency(15%)			260,865
Total			2,107,789

Approx. Elevation Difference

+16 m

Area 2

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of Force main	1700 m	330	561,000
Gas Pipeline Crossings	0 each	247,500	0
Rail Crossings	1 each	357,500	357,500
Creek Crossings	0 each	16,500	0
# of Lift Stations c/w genset	1 each	770,000	770,000
Road Reconstruction	1230 m	220	270,600
Service Road Construction	200 m	440	88,000
Highway Crossing	0	126,500	0
Telephone	200	33	6,600
Electricity	200	110	22,000
Water - municipal service	200	220	44,000
sub-total			2,119,700
Genral condition of contract			131,421
Contingency(15%)			317,955
Total			2,569,076

Approx. Elevation Difference

+9 m

Area 3

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of Force main	1700 m	330	561,000
Gas Pipeline Crossings	1 each	247,500	247,500
Rail Crossings	3 each	357,500	1,072,500
Creek Crossings	1 each	16,500	16,500
# of Lift Stations c/w genset	1 each	770,000	770,000
Road Reconstruction	0 m	220	0
Service Road Construction	300 m	440	132,000
Highway Crossing	1	126,500	126,500
Telephone	300 m	33	9,900
Electricity	300 m	110	33,000
Water - Municipal Service	300 m	220	66,000
sub-total			3,034,900
Genral condition of contract			188,164
Contingency(%)			455,235
Total			3,678,299

Approx. Elevation Difference

+20 m (potential for greater change depending on final location)

Area 4

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of Force main	3600 m	330	1,188,000
Gas Pipeline Crossings	0 each	247,500	0
Rail Crossings	3 each	357,500	1,072,500
Creek Crossings	1 each	16,500	16,500
# of Lift Stations c/w genset	1 each	770,000	770,000
Road Reconstruction	0 m	220	0
Service Road Construction	300 m	440	132,000
Highway Crossing	1	126,500	126,500
Telephone	300 m	33	9,900
Electricity	300 m	110	33,000
Water - on site well	1 each	11,000	11,000
sub-total			3,359,400
Genral condition of contract			208,283
Contingency(%)			503,910
	Total		4,071,593

Approx. Elevation Difference

+17 m

Area 5

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of Force main	4600 m	330	1,518,000
Gas Pipeline Crossings	0 each	247,500	0
Rail Crossings	3 each	357,500	1,072,500
Creek Crossings	1 each	16,500	16,500
# of Lift Stations c/w genset	1 each	770,000	770,000
Road Reconstruction	0 m	220	0
Service Road Construction	300 m	440	132,000
Highway Crossing	1 each	126,500	126,500
Telephone	300 m	33	9,900
Electricity	300 m	110	33,000
Water - on site well	1 each	11,000	11,000
sub-total			3,689,400
Genral condition of contract			228,743
Contingency(%)			553,410
	Total		4,471,553

Approx. Elevation Difference

+13 m

Estimates do not include:

Rock excavation if required.

Cost of on-site well will vary by depth and if treatment is required.

Table K7 - Lagoon Site Outfall Cost Estimate

Area 1

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of outfall	1065 m	330	351,450
Rail Crossings	2 each	357,500	715,000
outfall in the lake	600 m	880	528,000
sub-total			1,594,450
Genral condition of contract			111,612
contingency (15%)			239,168
Total			1,945,229

Area 2

Approximate Length of outfall	640 m	330	211,200
headwall	1 ea.	11,000	11,000
sub-total			222,200
Genral condition of contract			15,554
contingency (15%)			33,330
Total			271,084

Area 3

	Unit	Estimated Cost/Unit	Total Cost
Approximate Length of outfall	1800 m	330	594,000
Gas Pipeline Crossings	1 each	247,500	247,500
Rail Crossings	3 each	357,500	1,072,500
Creek Crossings	1 each	16,500	16,500
Highway Crossing	1	126,500	126,500
outfall in the lake	657 m	880	578,160
sub-total			2,635,160
Genral condition of contract			184,461
contingency (15%)			395,274
Total			3,214,895

Area 4 and 5

Approximate Length of outfall	625 m	330	206,250
Rail Crossings	1 each	357,500	357,500
headwall	1 each	11,000	11,000
Highway Crossing	1 each	126,500	126,500
sub-total			701,250
Genral condition of contract			49,088
contingency (15%)			105,188
Total			\$855,525

Table K8 - Annual O&M Cost Estimate Summary for Lagoon Treatment Process

	Annual Pumping Energy Cost	Annual Plant Process Energy Cost ¹	Annual Chemical Cost ²	Annual Labour Cost ³	Total Annual O&M Cost	20-Year O&M Costs ⁴
Area 1	\$26,546	\$42,629	\$23,313	\$17,000	\$109,000	\$2,180,000
Area 2	\$19,713	\$42,629	\$23,313	\$17,000	\$103,000	\$2,060,000
Area 3	\$35,485	\$42,629	\$23,313	\$17,000	\$119,000	\$2,380,000
Area 4	\$38,792	\$42,629	\$23,313	\$17,000	\$122,000	\$2,440,000
Area 5	\$37,061	\$42,629	\$23,313	\$17,000	\$120,000	\$2,400,000

Notes:

¹See Table K9 Annual Plant Process Energy Cost Estimate

²See Table K10 Annual Chemical Cost Estimate

³See Table K11 Aerated Lagoon Breakdown of Annual Labour Costs

⁴20-Year O&M Costs are calculated by multiplying the Annual O&M Cost by 20

Table K9 Annual Plant Process Energy Cost Estimate

Aerated Lagoon-Aspirator Operating Costs	Power (kW)	No. of Units Operating	Typ. Operating Hours (hrs)	Total Power per day (Kwh)
Equipment aspirators	3.73	9	24	805.68
chemical feed system	0.373	1	24	8.952
Plant Design daily average flow (cum/d)				900
overall efficiency				0.6975
Power costs per Kwh				0.1
Sub Total power cost/day				\$116.8
Estimated Annual Plant Process Energy Cost				\$42,629

Table K10 - Annual Chemical Cost Estimate

alum dose calculation

for 75% removal of P Alum to P weight ratio needed	15 Wat. & WW calc. manual P701
raw phosphorous concentration	4 mg/L
biological P uptake (10%)	0.4 mg/L
effluent P required	1 mg/L
P removal required	2.6 mg/L
daily phosphorous loading	2.34 kg/d
alum dosage	39 mg/L
average day plant flow	900000 L/d
daily alum required	35.1 kg/d
alum conc.	45 - 55 %
take conc. Alum	48.8 %
sp. Gravity of alum	1.335
conc. Alum	651480 mg/L
quantity of liquid alum needed per day	53.9 L/d
Quantity of alum daily required	2.2448886 L/hr.
Quantity of alum monthly required	53.9 L/d 1617 L/month
Total Cost (@\$1.185/L)	\$23,313.10

Table K11 - Aerated Lagoon Breakdown of Annual Labour Costs

item	Task	weekly Average (hr.)
1 INITIAL OVERALL INSPECTION		
a	quick visual inspection	0.56
b	check maintenance schedule	0.28
c	record maintenance jobs	0.25
2 CHECK AND MAINTAIN EQUIPMENT AND TANKS		
b	Maintain aerator equipment and pumps	
-	check equipment	0.28
-	oil change	0.06
h	chemical feed system maintenance	
-	inspect and adjust chemical feed system	0.67
-	clean chemical pump and feed line	0.25
-	refill chemical	0.25
3 PERFORM TESTS AND MAINTAIN OPERATIONAL LOG		
-	influent characteristics	0.14
-	aeration characteristics	0.56
-	clarifier characteristics	0.14
-	effluent characteristics	0.14
-	DO test	1.12
-	pH test	0.56
-	BOD test	0.4
-	suspended solids test	1
-	daily flow	0.56
-	other recordings	1.12
-	maintain books and test site, other test preparations & reports	1
4 MAKE OPERATIONAL ADJUSTMENTS		
-	remedial measures -other	0.5
5 FINAL AND PERIODIC OPERATION		
-	maintain control system	0.0625
-	clean up plant site	0.5
-	outside contacts and other maintenance	0.5
TOTALS		10.9 hr./week
rate		\$25 per hr.
		\$272.61
annual cost		\$17,011